

Lead Testing in School Drinking Water  
2017

School	Sample_No	Site	Type	ID_No	Labworks ID_No	Lead ug/L
<b>Al Tahoe School</b>	1	Kitchen Window Sink, right corner	Sink Fountain	0910002-AAC-A	AG55625	5.8
Al Tahoe School	2	MPR Drinking Fountain	Bottle Filler	0910002-AAC-B	AG55626	32
Al Tahoe School	3	Nurses Office fountain	Drinking Fountain	0910002-AAC-C	AG55627	0.82
Al Tahoe School	4	C-1 Classroom fountain	Drinking Fountain	0910002-AAC-D	AG55628	4.1
Al Tahoe School	5	B-5 Classroom fountain	Drinking Fountain	0910002-AAC-E	AG55629	4.9
<b>Bijou Elementary School</b>	1	Kitchen Window Sink	Sink Fountain	0910002-AAE-A	AG55630	0.83
Bijou Elementary School	2	MPR Bottle Filler	Bottle Filler	0910002-AAE-B	AG55631	ND
Bijou Elementary School	3	C-4 Classroom fountain	Drinking Fountain	0910002-AAE-C	AG55632	ND
Bijou Elementary School	4	D-Wing Lower fountain 1st floor, left	Drinking Fountain	0910002-AAE-D	AG55633	ND
Bijou Elementary School	5	B-3 Classroom fountain	Drinking Fountain	0910002-AAE-E	AG55634	ND
<b>Environmental Science Magnet School</b>	1	Kitchen sink (right side)	Sink Fountain	0910002-AAF-A	AG55635	0.86
Environmental Science Magnet School	2	B-Wing Hall Bottle Filler between A & B wings	Drinking Fountain	0910002-AAF-B	AG55636	ND
Environmental Science Magnet School	3	MPR Bottle Filler	Bottle Filler	0910002-AAF-C	AG55637	ND
Environmental Science Magnet School	4	Bottle Filler between B & C wings	Bottle Filler	0910002-AAF-D	AG55638	ND
Environmental Science Magnet School	5	A-5 Classroom fountain	Drinking Fountain	0910002-AAF-E	AG55639	ND
<b>South Tahoe Middle School</b>	1	Kitchen Sink by Walk-in Refrigerator	Sink Fountain	0910002-AAD-A	AG55640	0.65
South Tahoe Middle School	2	MPR bottle filler	Bottle Filler	0910002-AAD-B	AG55641	ND
South Tahoe Middle School	3	Echo Hall fountain, left	Drinking Fountain	0910002-AAD-C	AG55642	ND
South Tahoe Middle School	4	Room 15 fountain, left	Drinking Fountain	0910002-AAD-D	AG55643	ND
South Tahoe Middle School	5	Library fountain, right	Drinking Fountain	0910002-AAD-E	AG55644	1.1
<b>Sierra House Elementary School</b>	1	Kitchen Window Sink, right	Sink Fountain	0910002-AAH-A	AG55645	1.8
Sierra House Elementary School	2	MRP bottle filler	Bottle Filler	0910002-AAH-B	AG55646	ND
Sierra House Elementary School	3	Upper Pod Boys Bathroom fountain, right	Drinking Fountain	0910002-AAH-C	AG55647	ND
Sierra House Elementary School	4	Lower Pod Girls Bathroom fountain, right	Drinking Fountain	0910002-AAH-D	AG55648	ND
Sierra House Elementary School	5	Hallway outside MPR fountain	Bottle Filler	0910002-AAH-E	AG55649	ND
<b>Tallac High School</b>	1	Tallac Admin sink	Sink Fountain	0910002-AAB-A	AG55650	ND
Tallac High School	2	Student Union Kitchen Island Sink, center	Sink Fountain	0910002-AAB-B	AG55651	ND
Tallac High School	3	Student Union Water Station (right), center	Bottle Filler	0910002-AAB-C	AG55652	ND
Tallac High School	4	ABC C-Wing fountain, right	Drinking Fountain	0910002-AAB-D	AG55653	ND
Tallac High School	5	ABC A-Wing fountain, right	Drinking Fountain	0910002-AAB-E	AG55654	ND
<b>South Tahoe High School</b>	1	Tahoe Arts & Design Academy fountain off main lobby, right	Drinking Fountain	0910002-AAI-A	AG55655	ND
South Tahoe High School	2	Gym fountain in main hallway between boys and girls lockrs, left	Drinking Fountain	0910002-AAI-B	AG55656	ND
South Tahoe High School	3	Stadium View lower fountain 1st floor, left	Drinking Fountain	0910002-AAI-C	AG55657	ND
South Tahoe High School	4	Construction Arts & Transportation Building lower fountain 1st floor, left	Drinking Fountain	0910002-AAI-D	AG55658	ND
South Tahoe High School	5	Gym Upper Fountain at Sports Med Corridor, left	Drinking Fountain	0910002-AAI-E	AG55659	ND
<b>Tahoe Valley Elementary School</b>	1	Kitchen window Sink	Sink Fountain	0910002-AAG-A	AG55660	7.8
Tahoe Valley Elementary School	2	MPR bottle filler	Bottle Filler	0910002-AAG-B	AG55661	ND
Tahoe Valley Elementary School	3	A-1 classroom fountain	Drinking Fountain	0910002-AAG-C	AG55662	ND
Tahoe Valley Elementary School	4	A-6 classroom fountain	Drinking Fountain	0910002-AAG-D	AG55663	ND
Tahoe Valley Elementary School	5	B-14 classroom fountain	Drinking Fountain	0910002-AAG-E	AG55664	ND
<b>Repeats</b>						
Al Tahoe School	2	MPR Drinking Fountain - 1st Repeat	Bottle Filler	0910002-AAC-B	AG56220	41

Notes: Action Level (Limit) is 15 ug/L  
 ND means Not Detected at 0.5 ug/L  
 ug/L = micrograms per liter or parts per billion